

**APPENDIX A**  
**LOCATION MAP**

**WELLSBURG FIRE DEPARTMENT**

**CHEMUNG RIVER**

**PROPOSED SITE FOR NEW FIRE DEPARTMENT**

**ALTERNATE SITE FOR NEW FIRE DEPARTMENT**



**VILLAGE OF WELLSBURG FIRE HALL FLOOD DAMAGE LOCATION MAP**  
VILLAGE OF WELLSBURG, CHEMUNG COUNTY, NEW YORK

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	CATEGORY:	E
FIPS NO.	015-79081-00	PW REF NO.	7908104



Photo 1: Flood water behind the fire station.



Photo 2: Receding flood water front of the fire station



Photo 3: Damaged make shift 'bbq pit' - stacked cmu block with mortarless joint



Photo 4: Damaged insulated steel overhead door.

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104



Photo 5: Damaged Club room mini bar area.



Photo 6: Damaged Club room.



Photo 7: Damaged commercial kitchen range.



Photo 8: Damaged kitchen base cabinets.

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104



Photo 10: Damaged toilet room.



Photo 12: Damaged apparatus room.



Photo 11: Damaged state trooper's office.



Photo 12: Damaged furnace room.

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104



Photo 13: Apparatus building built in 1975. Building built by the Volunteer Fire Fighters. Photo taken 04/13/12.




Photo 14: Original building constructed in 1965. Photo taken 04/13/12.



Photo 15: Back side of the original building constructed in 1975. Photo taken 04/13/12.



Photo 16: Repaired graveled driveway on the side of the building (See yellow arrow marker in photo 14 for location of the driveway). Photo taken 04/13/12.

PHOTO SHEET

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104



DN.

Photo 17: Backside of the Apparatus Building. Photo taken 04/13/12



DN.

Photo 18: Club room. Photo taken 04/13/12.



DN.

Photo 19: Community room. Photo taken 04/13/12.



DN.

Photo 20: Apparatus room. Photo taken 04/13/12.

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104




Photo 21: Kitchen - Photo taken on 04/13/12.



Photo 22: Kitchen - Photo taken on - 4/13/12.





Photo 23: Repaired State Trooper's office - Photo taken on 04/13/12.



Photo 24: Fire Chief's office - Photo taken on 04/13/12.

**PHOTO SHEET**

APPLICANT:	Village of Wellsburg	DATE:	10/03/11
FIPS NO.	015-79081-00	PW REF NO.	7908104



Photo 25 - Underside of roof area above the Hallway. No structural or moisture damage. Photo taken 04/13/12



Photo 26: Underside of roof area above the Hallway. No structural or moisture damage. Photo taken 04/13/12



Photo 27 - Missing or deteriorated mortar joint at CMU block wall. Not a storm related damage. Photo taken 04/13/12



Photo 28 - Missing or deteriorated mortar joint at brick wall below the soffit. Not a storm related damage. Photo taken 04/13/12